

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**MYRTLE CREEK COMPLEX**  
**ANNEX**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734149	A1	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30
8734152	A2	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
BAND ROOM**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734145	OFF	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	3.5 ± 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**MYRTLE CREEK COMPLEX**  
**MCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734141	16	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	0.9 ± 0.2	2018-11-30
8734142	17	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.3 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
SKYHAWK**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734159	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	0.8 ± 0.2	2018-11-30
8734157	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	0.9 ± 0.2	2018-11-30
8734154	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	0.7 ± 0.2	2018-11-30
8734160	STAGE	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.0 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
INT BULIDING**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734164	22	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.8 ± 0.2	2018-11-30
8734168	23	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.7 ± 0.2	2018-11-30
8734161	24	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.8 ± 0.2	2018-11-30
8734166	25	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.7 ± 0.2	2018-11-30
8734163	27	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.8 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
MUSIC**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734147	BAND ROOM	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	3.2 ± 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
ANNEX**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734151	A1	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
SKYHAWK**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734158	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
INT BULIDING**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734165	22	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
MUSIC**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734148	BAND ROOM	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
ANNEX**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734153	A2	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	< 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
BAND ROOM**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734146	OFF	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	3.7 ± 0.3	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
MCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734143	17	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.4 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
SKYHAWK**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734155	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.1 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
INT BULIDING**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734167	25	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	0.6 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
ANNEX**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734150	A1	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.3 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
BAND ROOM**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734144	OFF	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	1.4 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPLEX  
SKYHAWK**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734156	MPR	2018-11-26 @ 6:00 am	2018-11-29 @ 6:00 am	1.4 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

December 3, 2018

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MYRTLE CREEK COMPOUND  
INT BULIDING**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
8734162	27	2018-11-26 @ 7:00 am	2018-11-29 @ 6:00 am	1.4 ± 0.2	2018-11-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498