

Water Testing Results - Coffenberry Middle School
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Down Stairs Drinking Fountain	19940300-003DW	6/8/2022	4
Staff Room Faucet	19940300-001SF	6/8/2022	5.3
Gym Concession Std Faucet	19940302-001CF	6/8/2022	ND
Gym NW Drinking Fountain	19940302-002DW	6/8/2022	ND
Gym NE Drinking Fountain	19940302-003DW	6/8/2022	ND
Gym SE Drinking Fountain	19940302-004DW	6/8/2022	ND
Concession Std Ice Maker	19940302-006IM	6/8/2022	ND
Track Drinking Fountain	19940302-005DW	6/8/2022	ND
Band Room Faucet	19940303-001CF	6/8/2022	1.1

Any fixture testing at or above the action level of 15 ppb is IMMEDIATELY removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			

ND = Non Detect - Lead level is below the set detection limits of X ppb