

## Water Testing Results - Coffenberry Middle School

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Main Hall Drinking Fountain		8/3/2016	2
Science Hall Drinking Fountain		8/3/2016	6
DW Stairs Drinking Fountain		8/3/2016	9
Track Drinking Fountain		8/3/2016	ND
Staff Room Faucet		8/3/2016	2
Gym Concession Std Faucet		8/3/2016	53
Gym NW Drinking Fountain		8/4/2016	ND
Gym NE Drinking Fountain		8/3/2016	ND
Gym SE Drinking Fountain		8/3/2016	ND
Band Room Faucet		9/7/2016	4
Concession Std Ice Maker		9/7/2016	ND