

Water Testing Results - Retesting

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
CV Annex Rm #1 Sink		8/22/2016	22
CV Annex Rm #1 Fountain		8/22/2016	8
CV Annex Rm #1 Faucet		9/9/2016	2
CV Annex Rm #2 Sink		12/2/2016	2
CV Annex #2 Fountain		12/2/2016	2
CV Annex #3 Sink		12/2/2016	ND
CV Annex #3 Fountain		12/2/2016	ND
Coffenberry Gym Concessions		2/2/2017	2
SUHS Football Concession		9/23/2016	14
SUHS DLC Fountain		2/2/2017	ND
SUHS Boys' Locker Room Fountain		2/2/2017	26
SUHS MPR Fountain		2/2/2017	ND
TCE Rm #17 Fountain		2/2/2017	3
CV Hilltop Staff Faucet		3/31/2017	ND
SUHS Girls' Locker Room Fountain		3/31/2017	ND
SUHS Boys' Locker Room Fountain		4/21/2017	ND
SUHS North FB Drink Fountain		4/21/2017	7
SUHS South FB Drink Fountain		4/21/2017	ND