

## Water Testing Results - South Umpqua H.S.

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
HS Sr. R/R Hall Fountain		7/21/2016	12
HS Sr. Hall Chill Fountain		7/18/2016	2
HS Kitchen Steamer Station		8/1/2016	3
HS Kitchen Baker Station		7/15/2016	11
HS Kitchen Cleaning Station		7/14/2016	10
HS Kitchen Prep S Station		7/18/2016	8
HS Blk MRK South Sink		7/21/2016	2
HS Cons Std Lg Sink		7/14/2016	ND
HS Cons Std. Sm Sink		7/26/2016	29
HS DLC Left Sink		8/1/2016	11
HS DLC Mid Sink		7/18/2016	5
HS DLC Right Sink		7/25/2016	5
HS DLC Hall Fountain		7/26/2016	59
HS Freshman Hall Fountain		7/14/2016	2
HS Office Hall Fountain		7/20/2016	4
HS Rm #22 Faucet		9/12/2016	ND
HS Rm #22 South Faucet		9/7/2016	49
HS Rm # 23 SE Faucet		9/8/2016	4
HS Rm #23 Mid Faucet		9/8/2016	3
HS Rm #23 NE Faucet		9/12/2016	3
HS Student Store Ice Machine		9/7/2016	ND
HS Jr. Concession Faucet		9/8/2016	40
HS Locker Room Ice Machine		9/7/2016	ND
HS Kitchen Ice Maker		9/7/2016	ND
HS Band Room Faucet		9/8/2016	2
HS Office Break Room Faucet		9/8/2016	2
HS Concession Std Ice maker		9/7/2016	2
HS JV Baseball Field		7/15/2016	10
HS V Baseball Field		7/15/2016	2
HS Track N Fountain		7/19/2016	ND
HS Track S Fountain		7/28/2016	30
HS Girls' Locker Room Fountain		7/20/2016	23.3
HS Boys' Locker Room Fountain		7/25/2016	23
HS Gym Fountain		7/21/2016	ND
HS Weight Room Fountain		7/14/2016	ND
HS MPR Fountain		7/18/2016	52
HS Dish Room Sink		7/20/2016	14